



NOTES

- SEWER SYSTEM SHALL BE LAYERED MORE THAN SIX (6) FEET FROM WATER MAINS.
- SEWER MAINS SHALL BE LAYERED MORE THAN SIXTY (60) FEET FROM A PORTABLE WATER WELL.
- DROP MANHOLES SHALL BE CONSTRUCTED WHEREVER INVERT OF INLET AND OUTLET OF MANHOLE EXCEEDS FIFTEEN (15) INCHES.
- A DIFFERENCE OF .05 FEET IN INVERTS ENTERING AND LEAVES MANHOLE IS PROVIDED.
- 1" = 200'

SYMBOLS

- MANHOLE
- LIFT STATION
- SEWER LINE
- FORCE MAIN
- 0.00 GROUND ELEVATION
- 0.00 PIPE INVERT ELEVATION & MANHOLE NO.
- S.D.L. SEWER DISTRICT LIMIT
- O.O.D. OUT OF DISTRICT
- EASEMENT LINE
- SEWER ENTRANCE
- N.G. ELEVATIONS